



**Termoplam Ltd.
Testing laboratory**

**Page number: 1
Number of pages: 12**

Republic of Bulgaria, Sofia,
<http://www.termoplam.eu>, e-mail: termoplam2011@abv.bg, GSM 0885 449 216

Test Report

**Nº 251
05.09.2022**

I. NAME AND SIGNATURE OF THE TESTED SAMPLE:

Production model: MEGAL-M17

II. NAME AND DESCRIPTION OF THE TESTED SAMPLE:

Wood heating boiler with a rated thermal output of 17 kW, one unit per test.

III. LEGAL DOCUMENT: EN 303-5:2021, EN 304:2017, EN 45001 and
EN ISO/IEC 17025:2018.



Picture of the sample

IV. QUANTITY OF THE TESTED SAMPLES: One test sample;

V. MANUFACTURER: "MEGAL" A.D, 17520 Bujanovac, Lopardinski put b.b, Serbia.


VI TEST APPLICANT: "MEGAL" A.D, 17520 Bujanovac, Lopardinski put b.b, Serbia.

VII. PURPOSE AND OBJECT OF THE TEST:

Heating boiler thermal test for defining of:

- 7.1. Nominal heat output;
- 7.2. Test for determining heating boiler efficiency.
- 7.3. Determining emissions from the heating boiler.
- 7.4. Pressure test of the boiler plumbing parts.
- 7.5. Calculation of the seasonal space heating emissions.
- 7.6. Calculation of the seasonal space heating energy efficiency.
- 7.7. Calculation of the energy efficiency index (EEI).

VIII. TECHNICAL FEATURES:



Scheme (drawing of the boiler)

- 8.1. Heat input Q_B - according to section 3.13 from EN 303-5:2021;
- 8.2. Thermal capacity P - according to section 3.6 from EN 303-5:2021;
- 8.3. Efficiency $\eta_K = P/Q_B$ - according to section 4.4.2 and 5.9.3 from EN 303-5:2021.
- 8.4. Boiler weight – without water/ volume of the water jacket:
8.4.1. MEGAL-M17 kW – 138 kg./ 32 l.;

IX. TEST CONDITIONS:

- 9.1. Executor: Termoplam Ltd. Sofia
- 9.2. Weather conditions: Ambient temperature t_L : $\leq 19/19^{\circ}\text{C}$ (from 15°C to 30°C according to section 5.6.1 of EN 303-5:2021).
- 9.3. Starting Date: 03.09.2022 y. Date of completion: 05.09.2022 y.
- 9.4. Weight of the pilot fuel:
 - 9.4.1. $B_n = 4.01 \text{ kg/h}$ (wood at rated heating output for two semi periods of 2 hour with continuous combustion according to 5.6.4.1 and 4.4.5 from EN 303-5:2021).
 - 9.4.2. $B_{red} = 1,33 \text{ kg/h}$ (wood at reduced heating output for two semi periods of 2 hour with continuous combustion according to 5.6.4.1 and 4.4.5 from EN 303-5:2021).
- 9.5. Draft (low pressure in the flue pipe) $\leq 0,15 \div 0,28 \text{ mbar}$ (see section 4.4.4 from EN 303-5:2021).
- 9.6. Fuel type:
 - 9.6.1. Wood with calorific value $H_u = 18320 \pm 60 \text{ kJ/kg}$ according to test report Nº 9298/30.05.2022 issued by the EUROTTEST - Control SA (see section 5.3 and table 9 from EN 303-5:2021 and specified in the maintenance book).
- 9.7. Temperature of outgoing water $84.3/84.0^{\circ}\text{C}$ (see section 5.7.2 from EN 303-5:2021).
- 9.8. Other conditions :
 - 9.8.1. The test is made under the conditions quoted above and observing the following additional ones:
 - 9.8.1.1. Complied with the safety measures according to EN 303-5:2021 and EN 304;

9.8.1.2. The tested sample meets the instruction for installation and operation according to EN 303-5:2021 and EN 304.

9.9. Used equipment - according to section 5.2 from EN 303-5:2021.

9.10. Recording devices:

9.10.1. Auxiliary devices: PC with software application package.

X. RESULTS FROM THE TEST:

10. Parametres.

10.1. Rated heating output of the boiler P_N according to section 3.7 from EN 303-5:2021.

10.2. Duration of the test rated heating output (two semi periods):

10.2.1. Wood duration of the test ≥ 2 h according to section 5.6.4.1 and 4.4.5 from EN 303-5:2021.

10.3. Maximum temperatures of the elements:

10.3.1 For heating boiler service:

10.3.1.1. Handle of the door ≤ 55.9 °C – according to 4.3.7 from EN 303-5:2021;

10.4. Real values of the thickness measurement, etc. with additional certificates enclosed.

10.5. After the test of the plumbing parts at pressure $p_{outg}=2xPS=2x2.5=5$ [bar] there are no leaks and visible deformations (elastic and plastic) in accordance with section 5.4.1 from EN 303-5:2021.

10.6. Temperature control and limiting devices according to section 4.3.9 from EN 303-5:2021:

The operating instructions on page 9 state that a safety valve (outside the boiler) must be installed.

On page 8 picture 1 of the installation and operating instructions there is a description of how to connect a boiler to the open system using a safety valve. A connection diagram and the necessary elements are shown.

In page 9 picture 2 of the installation and operating instructions, a description is provided on how to connect the boiler to the closed system using a safety valve. The scheme shown is for connection to these elements.

10.7. For calculation of the values of Q_B , P and η_k are used formulas from items 5.9.1, item 5.9.2 and item 5.9.3.2 from EN 303-5:2021.

* Values before the slash refer to the test at nominal power, and after it are for minimum power.

Table 1

Measurement	MEGAL-M17		Limit
Regime	nom	min	-
t_A °C	192	182	
t_L °C	≤19	≤19	15÷30
t_1 upper surface (average value)	≤50.3	≤45.6	≤60+ t_L * = 83
t_2 left wall (average value)	≤52.8	≤47.9	≤60+ t_L * = 83
t_3 right wall (average value)	≤56.7	≤48.5	≤60+ t_L * = 83
t_{floor} max	≤36.0	≤35.3	≤ 80 *
t upper handle	≤55.9	≤54.0	≤60+ t_L * = 83
t lower handle	-	-	≤60+ t_L * = 83
$P_{outg.}$ = 2xPS bar	5	5	= 5 bar
W_1 m ³ /h	772	252	-
t_V °C	84.3	84.0	-
t_R °C	65.4	65.0	70 ÷ 90
Bn kg/h	4.01	1.33	-
P kW	17.02	5.59	
Q_B kW	20.41	6.77	
$\eta_k = P/Q_B$ [%]	83.33	82.35	class 4
CO mg/m ³ ** at 10% O ₂	538.3	251.2	≤700
CO ₂ % vol. part.	8.41	7.73	-
OGC mg/m ³ at 10% O ₂ ***	24.7	21.8	≤ 30
Dust mg/m ³ at 10% O ₂ ****	53.8	45.8	≤60
W % ****	≤30	≤30	-
O ₂ % vol. part.	12.3	13.0	10
NOx mg/m ³ at 10% O ₂	174.3	140.9	
PN kW	17	-	-

* According to section 4.3.7 from EN 303-5:2021.

** Emission class 5 of the boiler at rated heating output ≤50 kW according to section 4.4.7 and table 7 from EN 303-5:2021.

*** Emission class 5 of the boiler at rated heating output ≤50 kW according to section 4.4.7 and table 7 from EN 303-5:2021.

**** Fuel – wood according to section 5.3, table 9 from EN 303-5:2021.

***** Emission class 5 of the boiler at rated heating output ≤50 kW according to section 4.4.7 and table 7 from EN 303-5:2021.

XI. Seasonal space heating emissions: acc. to table 8, Annex F from EN 303-5:2021, Annex II and Annex III of the REGULATION (EU) 2015/1189:

Table 2

Results	Model boiler	In accordance REGULATION (EU) 2015/1189.
	MEGAL-M17	[mg/Nm ³]
Dust [mg/Nm ³]	47	[PM] ¹ ≤ 60
CO [mg/Nm ³]	524	[CO] ² ≤ 700
OGC [mg/Nm ³]	22	[OGC] ³ ≤ 30
NO _x [mg/Nm ³]	146	[NO _x] ⁴ ≤ 200

Dust content of exhaust gases [PM]¹ ≤ 60 mg/Nm³ for manual stoked boilers in accordance with point 1 (c), of Annex II of the REGULATION (EU) 2015/1189.

CO of exhaust gases [CO]² ≤ 700 mg/Nm³ for manual stoked boilers in accordance with point 1 (e), of Annex II of the REGULATION (EU) 2015/1189.

OGC of exhaust gases [OGC]³ ≤ 30 mg/Nm³ for manual stoked boilers in accordance with point 1 (d), of Annex II of the REGULATION (EU) 2015/1189.

NO_x of exhaust gases [NO_x]⁴ ≤ 200 mg/Nm³ for biomass boilers in accordance with point 1 (f), of Annex II of the REGULATION (EU) 2015/1189.

XII. Seasonal space heating energy efficiency: acc. to Annex F from EN 303-5:2021, Annex II and Annex III of the REGULATION (EU) 2015/1189:

Table 3

Model boiler	Seasonal space heating energy efficiency η_s %	In accordance REGULATION (EU) 2015/1189 [η_s] [%]
MEGAL-M17	80	[η_s] ¹ ≥ 75

Where:

- η_s % - the seasonal space heating energy efficiency:

[η_s]¹ ≥ 75 % for boilers with a rated heat output of 20 kW or less in accordance with point 1 (a), of Annex II of the REGULATION (EU) 2015/1189.

XII. Energy efficiency index (EEI): acc. to Annex F from EN 303-5:2021, Annex II and Annex VIII of the REGULATION (EU) 2015/1187:

Table 3

Model boiler	Energy efficiency index EEI	Energy efficiency class
MEGAL-M17	117	A+

The energy efficiency index is calculated according to:

- 12.1. The requirements and the formulas of ANNEX VIII of REGULATION (EU) 2015/1187;
- 12.2. The energy efficiency index is calculated on the database provided by manufacturer for boiler burning wood;
- 12.3. The energy efficiency index is set for preferred fuel: wood according section 5.6.4.1 and section 5.3 from EN 303-5:2021.
- 12.4. Energy efficiency class is determined based on the energy efficiency index EEI according to Table 1 of ANNEX II of REGULATION (EU) 2015/1187.

XIII. ENCLOSURES:

- 13.1. Prints of the results from page 5.
- 13.2. Instruction for installation and operation - Yes.
- 13.3. Assembly drawing of the sample - 1.
- 13.4. Certificates (annexs A, B, C, D, and E): 5.



MANAGER:
(eng. Pl. Iliev)

NOTE:

The test results relate only to the tested samples.
Extracts from the test report can't be reproduced without written agreement of the testing laboratory.
This document is only informative.

Annex A

Certificate of steel sheet with a thickness of 5 mm


HBB GROUP Serbia Iron & Steel Co Belgrade, Bulevar Milana Ristic 6,
Belgrade-11000 Belgrade,
11000 Belgrade, Republic of Serbia



INSPECTION CERTIFICATE: 3.1 EN 10204:2004 PAGE No: 1
-uverenje o ispitivanju- (strana br):

Measured values of alpha and beta/gamma surface contamination of the examined goods are for alpha emitters lower than 4 Bq/100cm², as well as for beta/gamma emitters lower than 40 Bq/100cm².
We hereby declare that above mentioned products were manufactured in accordance with specifications and contract requirements.

QUALITY ASSURANCE



Annex C
Safety valve certificate



DECLARATION OF CONFORMITY

According to the Norms:
EN10204-2.1 & UNI EN ISO / IEC 17050-1

**The undersigned IVR S.p.A.
Producer of Hydrothermal Systems,
based in Boca (NO) Via Brughiera III no.1, Località Piano Rosa (Italy)**

DECLARES

Under its sole responsibility that the product

**Safety valve F/F
350 - 351 - 355 - 356 series**

Are built in accordance with the technical requirements and with the procedures established by the Company Quality Management System compliant with the UNI EN ISO 9001:2015 standard

Field of application:

- Maximum working pressure: 6 bar
- Calibration range:
 - 1/2" : 1,5 – 6,0 bar
 - 3/4" : 1,5 – 6,0 bar
 - 1" : 1,5 – 6,0 bar
- Operating temperature: +5°C / +110°C
- Standard calibration performed by the manufacturer: 6 bar

IVR S.p.A.
Legal Representative
Piero Giacomini
Piero Giacomini

April 20, 2022



Sede Amministrativa: Via Brughiera III n.1 Località Piano Rosa – 28010 BOCA (NO)

Sede Legale: Via Francesco Melzi d'Eril n.7 – 20154 MILANO (MI)

Codice Fiscale e Partita IVA 06829530960 – Registro Imprese di Milano n. 06829530960 – R.E.A. Milano n. 1918135

Tel. 0322 888811 – Fax 0322 888892-93 website www.ivrvalvole.it e-mail vendite@ivrvalvole.it / sales@ivrvalvole.it



Annex D
Certificate of welding electrode

**INSPECTION CERTIFICATE (3.1) - Chemical analysis
TEST REPORT (2.2) - Mechanical properties**

Date:	2021-11-15	Certificate number:	EC26619040 rev. 0
Our order:	0100368940	Your order:	13102021
Our reference:	Predrad Boricic (Serbia)	Your reference:	
Customer number:	HUE00050	Your fax number:	
Customer order date:	20211013	Your e-mail:	
Invoice address	Receiver of certificate	Delivery address	
STANISIC METAL DOO NIS KUBANSKA, 31 18000 NIS Serbia		STANISIC METAL DOO NIS KUBANSKA, 31 18000 NIS Serbia	
DELIVERY	Lot number:	SFV4510265	Quantity: 7524 KGM
PRODUCT		CHEMICAL COMPOSITION	
Brand:	ESAB	Actual results: acc to EN 10204 - 3.1	
Description:	OK 43.33 4.0x450mm		
Item number:	4333404400		
CLASSIFICATIONS		<u>All weld metal</u>	
SFA/AWS A5.1: E6013		C	0.08%
EN ISO 2560-A: E 42 0 RR 12		Si	0.35%
		Mn	0.5%
		P	0.025%
		S	0.009%
		Cr	< 0.1%
		Ni	< 0.1%
		Mo	< 0.1%
		Nb	0.01%
		Cu	< 0.1%
		V	0.02%
MECHANICAL PROPERTIES			
Typical data: acc to EN 10204 - 2.2			
Standard:			
Auxiliary:			
Condition:			

COMMENTS

Product supplied under a QA Programme fulfilling the EN ISO 9001 standard.
This certificate is produced electronically and is valid without signature.

Please refer any queries to:

ESAB Kft. 1083 Budapest, Bókay János u. 44-46., C6 épület, 7. emelet +36 1 382-12-00

Validation - Chemical Analysis

Péter Dránka

Quality Assurance Manager

Validation - Others

J-P Emoult

Product Manager

Annex E Certificate of seal

Извештај о испитивању број 612-22-4/14 страна 1 од укупно 3 стране



УНИВЕРЗИТЕТ У НИШУ
МАШИНСКИ ФАКУЛТЕТ
ЗАВОД ЗА МАШИНСКО ИНЖЕЊЕРСТВО
ЛАБОРАТОРИЈА ЗА ИСПИТИВАЊЕ
МАТЕРИЈАЛА И МАШИНА
18000 Ниш, ул. А. Медведева бр. 14, тел/факс 018/588-199
тел. 018/ 500-739, 500-696, 500-701 – руководилац Завода
e-mail: zavod@masfak.ni.ac.rs

ИЗВЕШТАЈ О ИСПИТИВАЊУ

бр. 612-22-19/14

ИСПИТИВАЊЕ СТАКЛЕНЕ ПЛЕТЕНИЦЕ

Наручилац:

«MILAN PEŠIĆ» D. O. O.

Производња ујади, канала, плетеница и мрежа
16203 Вучје, с. Брза

ПОДАЦИ О ПРОИЗВОДУ

Назив производа: СТАКЛЕНА ПЛЕТЕНИЦА
Година производње: 2014.
Попречни пресек: квадратни, правоугаони и огругли од 3 mm 90 mm.
Сировински састав: стаклено предиво.

ТЕХНИЧКЕ КАРАКТЕРИСТИКЕ

Радна температура: до 550 °C
Називни статички притисак: 100 daN/cm² (bar)

Резултати испитивања се односе само на испитане узорке.

Ниш, 27. 2. 2014. год.

Руководилац посла

Горан Раденковић, ван. проф.

